



EUROPEAN UTILITY REQUIREMENTS FOR LWR NUCLEAR POWER PLANTS

VOLUME 2

GENERIC AND NUCLEAR ISLAND REQUIREMENTS

CHAPTER 3

GRID REQUIREMENTS

Revision E
December, 2016

*The EUR promoters assume no liability
for any consequences of the use of any part of
the EUR document by a third party.*

List and status of the sections of the Chapter 2.3 Revision E, December 2016

GRID REQUIREMENTS

| <i>Section Number</i> | <i>Section Title</i> | <i>Last change</i> |
|-----------------------|---|--------------------|
| 2.3 | 1 INTRODUCTION TO THE GRID REQUIREMENTS | E-01 |
| 2.3 | 2 GENERAL CHARACTERISTICS | E-01 |
| 2.3 | 2.1 Unit sizing | E-01 |
| 2.3 | 2.1.1 Net unit capacity | E-01 |
| 2.3 | 2.1.2 Short-Circuit Capacity of the Grid | E-01 |
| 2.3 | 2.1.3 Main Grid Connection (400 kV) | E-01 |
| 2.3 | 2.1.4 Stand-by Grid Connection | E-01 |
| 2.3 | 2.2 Voltage and frequency ranges of operation | E-01 |
| 2.3 | 2.2.1 Rated frequency | E-01 |
| 2.3 | 2.2.2 Voltage-frequency ranges of operation for a unit | E-01 |
| 2.3 | 2.3 Harmonic distortion | E-01 |
| 2.3 | 2.4 Voltage and frequency range for synchronisation | E-01 |
| 2.3 | 3 OPERATION OF A UNIT UNDER NORMAL GRID CONDITIONS | E-01 |
| 2.3 | 3.1 Active power generation | E-01 |
| 2.3 | 3.1.1 Minimum load in continuous operation | E-01 |
| 2.3 | 3.1.2 Frequency Response in Frequency Sensitive Mode (FSM) | E-01 |
| 2.3 | 3.1.2.1 General parameters | E-01 |
| 2.3 | 3.1.2.2 Response time | E-01 |
| 2.3 | 3.1.2.3 Recovery time | E-01 |
| 2.3 | 3.1.2.4 Availability | E-01 |
| 2.3 | 3.1.3 Frequency Response in Limited Frequency Sensitive Mode - Overfrequency (LFSM - O) | E-00 |
| 2.3 | 3.1.4 Frequency Response in Limited Frequency Sensitive Mode - Underfrequency (LFSM -U) | E-00 |
| 2.3 | 3.2 Reactive power generation | E-01 |
| 2.3 | 3.2.1 General requirements | E-01 |
| 2.3 | 3.2.2 Voltage and reactive power transients | E-01 |
| 2.3 | 3.2.2.1 Transients induced by grid voltage variations | E-01 |
| 2.3 | 3.3 Steady - state stability | E-01 |
| 2.3 | 4 OPERATION OF A UNIT UNDER DISTURBED GRID CONDITIONS | E-01 |
| 2.3 | 4.1 Power output | E-01 |
| 2.3 | 4.2 Behaviour of the unit during grid faults | E-01 |
| 2.3 | 4.2.1 Fault Ride Through capabilities | E-01 |
| 2.3 | 4.2.2 Behaviour of the unit with voltage falling slowly | E-01 |
| 2.3 | 4.2.3 Behaviour of the unit during oscillations in the grid | E-01 |



List and status of the sections of the Chapter 2.3 Revision E, December 2016

GRID REQUIREMENTS

| <i>Section Number</i> | <i>Section Title</i> | <i>Last change</i> |
|-----------------------|--|--------------------|
| 2.3 5 | HOUSE LOAD OPERATION | E-01 |
| 2.3 5.1 | General requirement | E-01 |
| 2.3 5.2 | Criteria for automatic disconnection to house load | E-01 |
| 2.3 5.3 | Duration of house load operation | E-01 |
| 2.3 5.4 | Number of the disconnections to house load operation | E-01 |
| 2.3 6 | ISLAND OPERATION | D-08 |
| 2.3 6.1 | General requirements | E-01 |
| 2.3 6.2 | Operation after the changeover | E-01 |
| 2.3 7 | CONTRIBUTION OF A UNIT TO GRID RESTORATION | E-01 |
| 2.3 7.1 | Re-energising another unit | E-01 |
| 2.3 7.2 | Load steps | E-01 |
| 2.3 8 | CONNECTION BETWEEN A UNIT AND THE GRID | E-01 |
| 2.3 8.1 | Circuit breaker | E-01 |
| 2.3 8.2 | Transformer neutral point | E-01 |
| 2.3 8.3 | Lightning protection | E-01 |
| 2.3 8.4 | Protection equipment in the unit | E-01 |

